

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Empty enclosures.

Name and address of the applicant

Z.P.H. ELEKTRO-PLAST Sp. z o.o.
ul. Rogatka 14
62-860 Opatówek, Poland

Name and address of the manufacturer

Z.P.H. ELEKTRO-PLAST Sp. z o.o.
ul. Rogatka 14
62-860 Opatówek, Poland

Name and address of the factory

Z.P.H. ELEKTRO-PLAST Sp. z o.o.
ul. Rogatka 14
62-860 Opatówek, Poland

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

U_i: 500 V a.c.; U_i: 1000 V d.c.; IP65; IK07

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

RHp-8; RHp-12; RHp-18; RHp-24

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62208:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

LA-18.112/18.042/2/E

This CB Test Certificate is issued by the National Certification Body

BBJ-SEP
ul. M. Pożaryskiego 28
04-703 Warszawa
POLAND

Phone:

+48 22 812 69 38

Fax:

+48 22 815 65 80

e-mail:

bbj@bbj.pl



Signature:

Andrzej Rybski

Date: 2019-03-15

Address of the second factory: Z.P.H. ELEKTRO-PLAST Sp. z o.o.
ul. Szosa Konińska 4
62-820 Stawiszyn, Poland

List of types:

Type	Catalogue No.	Dimensions [mm]			Thermal power dissipation capability acc. IEC TR 60890:2014 [W]
		Width	Height	Depth	
RHp-8	36.808	290	260	135	28,1
RHp-12	36.120	290	330	135	34,6
RHp-18	36.180	290	435	135	44,1
RHp-24	36.240	450	330	135	46,6

Version: transparent doors.

For indoor use.

For installation in combustion-resistant walls, flush mounting.

Range of ambient temperature: - 25 °C + + 60 °C.

IP65 - with the enclosure door closed.

Additional information (if necessary)



Date: 2019-03-15

A. Rybski

Signature: Andrzej Rybski